



Matthew G. Bevin  
Governor

Charles G. Snaveley  
Secretary  
Energy and Environment Cabinet

Commonwealth of Kentucky  
**Public Service Commission**

211 Sower Blvd.  
P.O. Box 615  
Frankfort Kentucky 40602-0615  
Telephone: (502) 564-3940  
Fax: (502) 564-3460  
psc.ky.gov

January 13, 2017

Michael J. Schmitt  
Chairman

Robert Cicero  
Vice Chairman

Daniel E. Logsdon Jr.  
Commissioner

**PARTIES OF RECORD**

RE: Case No. **2016-00421**

Muhlenberg County Water District #3  
(Deviation)  
807 KAR 5:066, Section 4(4)

The Commission Staff has reviewed the filing submitted December 14, 2016 and has determined that the application in the above case now meets the minimum filing requirements. Attached please find a stamped filed copy of the first page of your filing. This case has been docketed and will be processed as expeditiously as possible.

If you need further assistance, please contact my staff at 502-564-3940.

Sincerely,

Talina R. Mathews  
Executive Director

TM/rs

**FILED**  
DEC 14 2016  
PUBLIC SERVICE  
COMMISSION

**RECEIVED**

DEC 2 2016

Public Service  
Commission

**KENTUCKY PUBLIC SERVICE COMMISSION**

Water Storage Requirement Deviation Request Application

**807 KAR 5:066, Section 4(4): Storage.** *The minimum storage capacity for systems shall be equal to the average daily consumption.*

This form is intended to assist water utilities seeking a deviation from the requirements of 807 KAR 5:066, Section 4(4) and for permission to either maintain less water storage capacity than the average daily consumption or to obtain additional time to attain minimum storage capacity equal to the average daily consumption.

To request a deviation from the requirements of 807 KAR 5:066, Section 4(4), please complete the following application in full.

Utility: Muhlenberg County Water District #3

Address: PO Box 67 4789 Main Street

City: Bremen State: KY Zip Code: 42325

Telephone Number: ( 270 ) 525-6333 Number of Customers: 2117

County or Counties served: Muhlenberg McLean ( City of Sacramento)

Are you requesting a deviation:

(  ) To maintain less water storage capacity than the average daily consumption?

(  ) For additional time to attain minimum storage capacity equal to the average daily consumption?

\*Ben Tooley  
Muhlenberg County Water District #3  
P. O. Box 67  
Bremen, KY 42325

\*Muhlenberg County Water District #3  
4789 Main Street  
P. O. Box 67  
Bremen, KY 42325

\*Dennis Winters  
128 W. Morehead Street  
Central City, KENTUCKY 42330